

OVE Austrian Electrotechnical Association
Eschenbachgasse 9 | 1010 Wien | Austria
ZVR: 327279890 | www.ove.at



OVE Testing and Certification
Kahlenberger Str. 2A | 1190 Wien | Austria
T +43 1 370 58 06 | certification@ove.at

ENEC Certification Body registered under ID # 11.

Validity of ENEC Licences can be checked at www.enec.com

LICENCE

to use the European Mark



Licence No.: **7590-250**

Date of issue: Wien, 2019 06 12
Rev. No.: 02 Wien, 2020 12 21

OVE the Austrian Electrotechnical Association as signatory to the **"Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards"** hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licenceholder: **Tridonic GmbH & Co KG**
Färbergasse 15
6851 Dornbirn
Austria

Product: **Electronic control gears for LED-modules**

Trade Mark: **TRIDONIC**

Series/Type: **LC ... 24V one4all .. PRE .., LCA ... 24V one4all .. PRE ..**

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Österreichischer Verband für Elektrotechnik
Head of Testing and Certification

Digitally signed by W. Martin
Email=w.martin@ove.at
Dipl.-Ing. W. Martin



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



| | |
|--|--|
| <i>Hersteller Manufacturer</i> | Tridonic GmbH & Co KG Färbergasse 15 6851 Dornbirn Austria |
| <i>Fertigungsstätte(n) Factory location(s)</i> | ID: 7590 |
| * <i>Typenbezeichnung Type reference</i> | LC ... 24V one4all .. PRE ..., LCA ... 24V one4all .. PRE ..., see page 4 |
| * <i>Prüfbericht Test Report</i> | TGM-VA EE 36771j ECS-2, TGM-VA EE 36771k ECS-1/ECS-2, TGM-VA EE 36771l ECS-1/ECS-2, TGM-VA EE 36771m ECS-1/ECS-2, TGM-VA EE 38152 ECS-1, TGM-VA EE 36771b ECS-2, TGM-VA EE 38153 ECS-1, TGM-VA EE 38567 ECS-1/ECS-2, TGM-VA EE 38568 ECS-1/ECS-2, TGM-VA EE 38569 ECS-1/ECS-2 |
| <i>Nationale Bestimmung(en) National Standard(s)</i> | OVE EN 61347-1:2016-06-01 OVE EN 61347-2-13:2017-11-01 |
| <i>Europannorm(en) European Standard(s)</i> | EN 61347-1:2015 EN 61347-2-13:2014 + A1:2017 EN 62384:2006 + A1:2009 |
| * <i>Ersatz für Zertifikat Superseded licence</i> | 7590-250 Rev. 01 dated 2020 10 06 Items modified are marked with an asterisk (*) |
| <i>Anmerkung(en) Remark(s)</i> | Complies with the additional requirements for emergency lighting according Annex J of EN 61347-2-13:2014+A1:2017. CTF Stage 2 |

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

| | |
|---|--|
| <i>Nennspannung</i> <i>Rated voltage</i> | AC 220-240 V, 50/60 Hz; DC 220-240 V |
| <i>Bemessungs-Ausgangsspannung</i> <i>Rated output voltage</i> | DC 24 V |
| <i>Nennleistung</i> <i>Rated power</i> | see page 4 |
| <i>Schutzklasse</i> <i>Class of protection</i> | CI.II (only for independent controlgears) |
| <i>Max. Betriebstemperatur tc</i> <i>Rated max. operating temperature tc</i> | see page 4 |
| <i>Umgebungstemperatur ta</i> <i>Rated ambient temperature ta</i> | see page 4 |
| * <i>Maximale Gehäusetemperatur</i> <i>Rated maximum case temperature</i> | see page 4 |
| <i>Kurzschlußschutz</i> <i>Short-circuit protection</i> | Inherently short circuit proof controlgear |
| <i>Klassifikation</i> <i>Classification</i> | Electronic controlgears providing SELV, constant voltage type |

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

| TRADEMARK / TYPECODE | | Classification: B...Built-in I....Independent | Rated output voltage | Rated output power | Rated max. operating temperature (tc) ¹ | Maximum ambient temperature (ta) ¹ | Maximum case temperature | Circuit power factor (230V, 50Hz, full load) | Case | |
|----------------------|----|---|----------------------|--------------------|---|--|-----------------------------|---|--------------------------|---|
| TRIDONIC | | | | | | | | | Metal (M) Plastic (P) | |
| | | | [V] | [W] | [°C] | [°C] | [°C] | λ | | |
| * | 1 | LC 18W 24V one4all SC PRE | B ² | 24 | 2,7-18 | 70/75 | 50/55/60 | 110 | 0,95 | P |
| * | 2 | LC 18W 24V one4all SC PRE SP | B ² | 24 | 2,7-18 | 70/75 | 50/55/60 | 110 | 0,95 | P |
| * | 3 | LC 18W 24V one4all Ip PRE | B | 24 | 2,7-18 | 70/75 | 65/70 | 110 | 0,95 | M |
| | 4 | LCA 35W 24V one4all SC PRE | B | 24 | 3,5-35 | 75/80 | 50/60 | 110 | 0,98 | P |
| | 5 | LCA 35W 24V one4all SC PRE SP | B ² | 24 | 3,5-35 | 75/80 | 50/60 | 110 | 0,98 | P |
| * | 6 | LC 35W 24V one4all Ip PRE | B | 24 | 3,5-35 | 75 | 60/65/70 | 110 | 0,97 | M |
| | 7 | LCA 60W 24V one4all SC PRE | B ² | 24 | 6-60 | 75 | 50/55/60 | 110 | 0,98 | P |
| | 8 | LCA 60W 24V one4all SC PRE SP | B ² | 24 | 6-60 | 75 | 50/55/60 | 110 | 0,98 | P |
| * | 9 | LC 60W 24V one4all Ip PRE | B | 24 | 6-60 | 75/80 | 60/65/70 | 130 | 0,98 | M |
| | 10 | LCA 100W 24V one4all SC PRE | I | 24 | 100 | 80 | 45/50 | 110 | 0,99 | P |
| | 11 | LCA 100W 24V one4all SC PRE SP | I | 24 | 100 | 80 | 45/50 | 110 | 0,99 | P |
| | 12 | LCA 100W 24V one4all Ip PRE | B | 24 | 10-100 | 75/80 | 60/65/70 | 110 | 0,99 | M |
| | 13 | LCA 150W 24V one4all SC PRE | I | 24 | 15-150 | 80/85/90 | 50/55/60 | 110 | 0,99 | P |
| | 14 | LCA 150W 24V one4all SC PRE SP | I | 24 | 15-150 | 80/85/90 | 50/55/60 | 110 | 0,99 | P |

¹ Depending on output power, see marking on product or datasheet (listed values valid for full load).

² With strain reliefs and terminal cover also useable as independent controlgear.

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.