

TE-DC 2 0300 F101 300 VA with current guard



Field of application

Surface-mounted transformer for low-voltage halogen systems, 12 V

Functions of the protective devices

The device is fitted with a microprocessor-controlled current guard. The power output on the secondary output is measured on the primary input by the current guard during commissioning and stored as a reference value.

In the event of deviations from the reference value of ± 40 W as a result of overload or short-circuit, the output circuit will be disconnected for safety reasons. If the source of the fault is not removed, the current guard will be disconnected within 1 second of closing. If short-circuiting occurs, it will not be possible to switch on the system again.

A temperature relay is installed as additional protection for the DC transformer. In the event of overload, the output voltage will be reduced in order to lower the temperature of the device. Should the temperature still continue to rise, the device will be disconnected. When the correct operating temperature for the transformer is reached, the transformer starts automatically.

Read the assembly instructions carefully before initial commissioning!



1. Switch off your transformer at the switch.
2. Turn the switch on and off 3 times. The switch must be on or off for less than 1 second. The connected lamp output will be stored as a reference value.
3. To acknowledge the storage TE-DC will dim from minimum dim-level to maximum dim-level. This process takes about 10 seconds. A user intervention (e.g. dimming command) during this time will abort the commissioning for safety reasons (e.g. playing children).
If the reference commissioning was successful, TE-DC will continue to operate with the minimum dim-level. Commissioning is then complete. In case of a fault the TE-DC will switch off.
4. In the event of a malfunction, repeat from point 1.

Changing the lamp output

1. Switch off the transformer at the switch.
2. Connect the desired number of lamps. In doing so, observe the maximum TE-DC transformer output.
3. Turn the switch on and off 3 times. The switch must be on for less than 1 second. The connected lamp output will be stored as a new reference value.
4. To acknowledge the storage TE-DC will dim from minimum dim-level to maximum dim-level. This process takes about 10 seconds. A user intervention (e.g. dimming command) during this time will abort the commissioning for safety reasons (e.g. playing children). If the reference commissioning was successful, TE-DC will continue to operate with the minimum dim-level. Commissioning is then complete. In case of a fault the TE-DC will switch off.
5. In the event of a malfunction, repeat from point 1.

Possible faults during operation

If the current guard detects insufficient load, the light flashes every 15 seconds briefly. This allows to detect defective light sources. Switch off the transformer then and remove the source of the fault. Afterwards the system can be reconnected unless the connected lamp output has not changed.

On overload the transformer will switch off and can be restarted with off/on.

Possible operating faults

Foreign objects between conductors. Faulty / defective terminals, conductors and lamp ways, insufficient load on secondary or too great a load, short-circuit, faulty lamps, power circuit interruptions.

Re-commissioning: remove fault source, switch lighting system on.

Characteristics of surface-mounted transformer

Technical data:	see data sheet
Housing:	polycarbonate
Tested in accordance with:	EN 61347-2-2, EN 61047, EN 55015, EN 61000-3-2, EN 61547, VDE 0710-14
Protection:	Class II
Test symbol:	
Dimmer:	not provided
Conformity:	CE

Assembly instructions

Installation and assembly to be carried out by an authorised / competent individual.

Nominal voltage:	230 – 240 V primary
Nominal frequency:	50/60/0 Hz
Nominal lamp wattage:	100 – 300 W
Earthing:	The connection of or protective earth is not required (protection class II transformer)
Fixing:	max. diameter 6 mm or M6, min. length 25 mm fixing centres 218 – 226 mm
Fixing to the DIN rail:	Utilise screws provided or round head screws; max. 3.5 – 4 mm dia. (no countersunk head screws); DIN 7981C 3.5 x 16


Installation Requirements:	dry, acid-free, oil-free, grease-free 35 °C (max. ambient temperature)
Mounting surface:	level, can be mounted on combustible materials

Max. rating of miniature circuit-breakers (B, C)

Min. circuit-breakers	10 A	13 A	16 A	20 A
Installation \varnothing	1.5 mm ²	1.5 mm ²	2.5 mm ²	2.5 mm ²
TE-DC 2 0300 F101	6	8	10	13

Due to the low in-rush current only the nominal operating current needs to be considered.

Minimum spacing (mm):



Recommended conductor cross-section – primary:

0.75 – 2.5 mm², light plastic-sheathed cable with a min. Ø (external) of 6 mm

-  **rigid wires:** 1 x 2.5 mm²
2 x 1.5 mm²
-  **flexible wires:** 1 x 2.5 mm²
2 x 1.5 mm²

Recommended conductor cross-section/max. length – secondary:

2.5 – 10.0 mm²

Output VA	Current A	Line length from transformer to lamp			
		5 m	10 m	15 m	20 m
		Line cross-section in mm ²			
100	8.3	2.5	4.0	6.0	10.0
150	12.5	2.5	6.0	10.0	10.0
210	17.5	4.0	10.0	10.0	10.0
250	20.8	4.0	10.0	10.0	10.0
300	25.0	6.0	10.0	10.0	10.0

These values apply to flexible copper conductors.


Note: Long feeders, connecting elements and couplings represent a higher electrical resistance and reduce the line lengths specified above.




Min. thermal stability of the secondary conductor 100 °C
Tighten terminals firmly!

Length of the wires to be stripped of insulation (mm):

Primary:



Secondary:



Installation instructions:

H03VV-F, H05VV-F



Safety instructions:

Installation of this device may only be carried out by specialist staff who have provided proof of their skills. The power supply must be switched off before handling the device. The relevant safety and accident prevention regulations must be observed.

DC operation:

The TE-DC can be operated using DC voltage in installations in accordance with EN 50172.

Strain relief:

- Wide adjustment range for strain relief (3 – 12 mm)
- Rapid installation of strain relief and terminal cover in the shortest possible time without having to use any tools
- Do not feed single insulated conductors through the strain relief on the primary side



Primary side



Secondary side



Ceiling mounting



Ceiling mounting



Closing



Opening



Intelligent Voltage Guard:

Intelligent Voltage Guard is the name of the new electronic monitor from TridonicAtco. This innovative feature of the TE-DC family of control gear from TridonicAtco immediately shows if the mains voltage rises above or falls below certain thresholds. Measures can then be taken quickly to prevent damage to the control gear.

- If the mains voltage rises above 290 V the lamps start flashing on and off.
- This signal "demands" disconnection of the power supply to the lighting system.
- If the mains voltage falls below 180 V the control gear will automatically dim down to 10 % to protect the control gear from being irreparably damaged.

Data secondary terminal:

possible Wiring

Clamping area	0.33 ... 16.00 mm ²
Single wire / H05(07) V-U	0.5 ... 16.00 mm ²
braided wire / H05(07) V-K	0.5 ... 10.00 mm ²
braided wire / DIN 46228-1	2.5 ... 10.00 mm ²
braided wire / DIN 46228-4	2.5 ... 10.00 mm ²
plug gage / EN 60999	Ø 5.3 (B6)

